



NOTES:

1. TRACER WIRE FOR PVC PIPE SHALL BE NO. 10 AWG GAUGE COATED COPPER WIRE AND ALL SPLICES SHALL BE MADE WITH A MECHANICAL WATER PROOF CONNECTION.
2. TRACER WIRE SHALL COME UP ON VALVE EXTENSIONS AND FIRE HYDRANT VALVES.
3. TRACER WIRE MUST BE "DUCT" TAPED TO THE WATER MAIN PIPE AT INTERVALS NOT TO EXCEED TEN (10)-FEET AND TAPE WRAPPED AROUND MAIN TWICE.

THE CITY OF ROSENBERG, FORT BEND COUNTY, TEXAS
DEPARTMENT OF PUBLIC WORKS

TRACER WIRE FOR PLASTIC WATER PIPING

DESIGN:	CAD:	SCALE:	DATE:	DRAWING:
CAK	STAFF	NTS	02/11	W-110